

**FEDERALLY ENFORCEABLE STATE
OPERATING PERMIT (FESOP)
OFFICE OF AIR MANAGEMENT**

**Hartford City Paper, L.L.C.
501 South Spring
Hartford City, Indiana 47348**

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-8 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.

Operation Permit No.: F009-7409-00016	
Issued by: Paul Dubenetzky, Branch Chief Office of Air Management	Issuance Date:

SECTION A SOURCE SUMMARY

- A.1 General Information [326 IAC 2-8-3(b)]
- A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]
- A.3 Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(I)]
- A.4 FESOP Applicability [326 IAC 2-8-2]
- A.5 Prior Permit Conditions

SECTION B GENERAL CONDITIONS

- B.1 Permit No Defense [IC 13]
- B.2 Definitions [326 IAC 2-8-1]
- B.3 Permit Term [326 IAC 2-8-4(2)]
- B.4 Enforceability [326 IAC 2-8-6]
- B.5 Termination of Right to Operate [326 IAC 2-8-9][326 IAC 2-8-3 (h)]
- B.6 Severability [326 IAC 2-8-4(4)]
- B.7 Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]
- B.8 Duty to Supplement and Provide Information [326 IAC 2-8-3(f)] [326 IAC 2-8-4(5)(E)]
- B.9 Compliance Order Issuance [326 IAC 2-8-5(b)]
- B.10 Compliance with Permit Conditions [326 IAC 2-8-4(5)(A)] [326 IAC 2-8-4(5)(B)]
- B.11 Certification [326 IAC 2-8-3(d)] [326 IAC 2-8-4(3)(C)(i)] [326 IAC 2-8-5(1)]
- B.12 Annual Compliance Certification [326 IAC 2-8-5(a)(1)]
- B.13 Preventive Maintenance Plan [326 IAC 1-6-3][326 IAC 2-8-4(9)][326 IAC 2-8-5(a)(1)]
- B.14 Emergency Provisions [326 IAC 2-8-12]
- B.15 Deviations from Permit Requirements and Conditions [326 IAC 2-8-4(3)(C)(ii)]
- B.16 Permit Modification, Reopening, Revocation and Reissuance, or Termination
- B.17 Permit Renewal [326 IAC 2-8-3(h)]
- B.18 Permit Amendment or Modification [326 IAC 2-8-10][326 IAC 2-8-11.1]
- B.19 Operational Flexibility [326 IAC 2-8-15]
- B.20 Construction Permit Requirement [326 IAC 2]
- B.21 Inspection and Entry [326 IAC 2-8-5(a)(2)]
- B.22 Transfer of Ownership or Operation [326 IAC 2-8-10]
- B.23 Annual Fee Payment [326 IAC 2-8-4(6)] [326 IAC 2-8-16]

SECTION C SOURCE OPERATION CONDITIONS

Emission Limitations and Standards [326 IAC 2-8-4(1)]

- C.1 Overall Source Limit [326 IAC 2-8]
- C.2 Opacity [326 IAC 5-1]
- C.3 Open Burning [326 IAC 4-1][IC 13-17-9]
- C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2(3)]
- C.5 Fugitive Dust Emissions [326 IAC 6-4]
- C.6 Operation of Equipment [326 IAC 2-8-5(a)(4)]
- C.7 Stack Height [326 IAC 1-7]
- C.8 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61.140]

Testing Requirements [326 IAC 2-8-4(3)]

- C.9 Performance Testing [326 IAC 3-6]

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

- C.10 Compliance Monitoring [326 IAC 2-8-4(3)] [326 IAC 2-8-5(a)(1)]
- C.11 Maintenance of Monitoring Equipment [326 IAC 2-8-4(3)(A)(iii)]
- C.12 Monitoring Methods [326 IAC 3]

Corrective Actions and Response Steps [326 IAC 2-8-4] [326 IAC 2-8-5]

- C.13 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]
- C.14 Risk Management Plan [326 IAC 2-8-4] [40 CFR 68.215]
- C.15 Compliance Monitoring Plan - Failure to Take Response Steps [326 IAC 2-8-4]
- C.16 Actions Related to Noncompliance Demonstrated by a Stack Test

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]

- C.17 Monitoring Data Availability
- C.18 General Record Keeping Requirements [326 IAC 2-8-4(3)][326 IAC 2-8-5]
- C.19 General Reporting Requirements [326 IAC 2-8-4(3)(C)]

Stratospheric Ozone Protection

- C.20 Compliance with 40 CFR 82 and 326 IAC 22-1

SECTION D.1 FACILITY OPERATION CONDITIONS - Two (2) Natural Gas Fired Boilers

Emission Limitations and Standards [326 IAC 2-8-4(1)]

- D.1.1 Particulate Matter Limitation (PM) [326 IAC 6-2-4]
- D.1.2 FESOP Limit [326 IAC 2-8]
- D.1.3 Sulfur Dioxide (SO₂) [326 IAC 7-1.1-1] [326 IAC 12-1]
- D.1.4 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

Compliance Determination Requirements

- D.1.5 Testing Requirements [326 IAC 2-8-5(a)(1), (4)][326 IAC 2-1.1-11]
- D.1.6 Sulfur Dioxide Emissions and Sulfur Content

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

- D.1.7 Visible Emissions Notations

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

- D.1.8 Record Keeping Requirements
- D.1.9 Reporting Requirements

Certification Form

Emergency/Deviation Form

Natural Gas Fired Boiler Certification

Quarterly Report Form

Quarterly Compliance Monitoring Report Form

SECTION A SOURCE SUMMARY

This permit is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Management (OAM). The information describing the source contained in conditions A.1 through A.3 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this permit pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

A.1 General Information [326 IAC 2-8-3(b)]

The Permittee owns and operates a stationary paper recycling facility utilizing two (2) natural gas-fired boilers using no. 2 fuel oil as backup.

Authorized individual: Neil Burchard
Source Address: 501 South Spring, Hartford City, IN 47348
Mailing Address: P.O. Box 30, Hartford City, IN 47348
Phone Number: (765) 348-5440
SIC Code: 2631
County Location: Blackford
County Status: Attainment for all criteria pollutants
Source Status: Federally Enforceable State Operating Permit (FESOP)
Minor Source, under PSD or Emission Offset Rules;
Minor Source, Section 112 of the Clean Air Act

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-8-3(c)(3)]

This stationary source consists of the following emission units and pollution control devices:

- (a) One (1) natural gas fired boiler (using no. 2 fuel oil as backup, with a maximum sulfur content of 0.5%), identified as Boiler 1, with a maximum heat input rate of 67.5 million (MM) British thermal units (Btu) per hour, and exhausting through stack 1; and
- (b) One (1) natural gas fired boiler (using no. 2 fuel oil as backup, with a maximum sulfur content of 0.5%), identified as Boiler 2, with a maximum heat input rate of 45.7 MMBtu per hour, and exhausting through stack 2.

A.3 Insignificant Activities [326 IAC 2-7-1(21)] [326 IAC 2-8-3(c)(3)(I)]

This stationary source does not currently have any insignificant activities, as defined in 326 IAC 2-7-1(21).

A.4 FESOP Applicability [326 IAC 2-8-2]

This stationary source, otherwise required to have a Part 70 permit as described in 326 IAC 2-7-2(a), has applied to the Indiana Department of Environmental Management (IDEM), Office of Air Management (OAM) for a Federally Enforceable State Operating Permit (FESOP).

A.5 Prior Permit Conditions

- (a) This permit shall be used as the primary document for determining compliance with applicable requirements established by previously issued permits.
- (b) If, after issuance of this permit, it is determined that the permit is in nonconformance with an applicable requirement that applied to the source on the date of permit issuance, including any term or condition from a previously issued construction or operation permit, IDEM, OAM, shall immediately take steps to reopen and revise this permit and issue a compliance order to the Permittee to ensure expeditious compliance with the applicable requirement until the permit is reissued.

SECTION B GENERAL CONDITIONS

B.1 Permit No Defense [IC 13]

Indiana statutes from IC 13 and rules from 326 IAC, quoted in conditions in this permit, are those applicable at the time the permit was issued. The issuance or possession of this permit shall not alone constitute a defense against an alleged violation of any law, regulation or standard, except for the requirement to obtain a FESOP under 326 IAC 2-8.

B.2 Definitions [326 IAC 2-8-1]

Terms in this permit shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, any applicable definitions found in IC 13-11, 326 IAC 1-2, and 326 IAC 2-7 shall prevail.

B.3 Permit Term [326 IAC 2-8-4(2)]

This permit is issued for a fixed term of five (5) years from the effective date, as determined in accordance with IC 4-21.5-3-5(f) and IC 13-15-5-3.

B.4 Enforceability [326 IAC 2-8-6]

- (a) All terms and conditions in this permit, including any provisions designed to limit the source's potential to emit, are enforceable by IDEM.
- (b) Unless otherwise stated, terms and conditions of this permit, including any provisions to limit the source's potential to emit, are enforceable by the United States Environmental Protection Agency (U.S. EPA) and citizens under the Clean Air Act.

B.5 Termination of Right to Operate [326 IAC 2-8-9] [326 IAC 2-8-3(h)]

The Permittee's right to operate this source terminates with the expiration of this permit unless a timely and complete renewal application is submitted at least nine (9) months prior to the date of expiration of the source's existing permit, consistent with 326 IAC 2-8-3(h) and 326 IAC 2-8-9.

B.6 Severability [326 IAC 2-8-4(4)]

The provisions of this permit are severable; a determination that any portion of this permit is invalid shall not affect the validity of the remainder of the permit.

B.7 Property Rights or Exclusive Privilege [326 IAC 2-8-4(5)(D)]

This permit does not convey any property rights of any sort, or any exclusive privilege.

B.8 Duty to Supplement and Provide Information [326 IAC 2-8-3(f)] [326 IAC 2-8-4(5)(E)]

- (a) The Permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall promptly submit such supplementary facts or corrected information to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Management
100 North Senate Avenue, P.O. Box 6015
Indianapolis, Indiana 46206-6015

- (b) The Permittee shall furnish to IDEM, OAM, within a reasonable time, any information that IDEM, OAM, may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit.

- (c) Upon request, the Permittee shall also furnish to IDEM, OAM, copies of records required to be kept by this permit. If the Permittee wishes to assert a claim of confidentiality over any of the furnished records, the Permittee must furnish such records to IDEM, OAM, along with a claim of confidentiality under 326 IAC 17. If requested by IDEM, OAM, or the U.S. EPA, to furnish copies of requested records directly to U. S. EPA, and if the Permittee is making a claim of confidentiality regarding the furnished records, the Permittee must furnish such confidential records directly to the U.S. EPA along with a claim of confidentiality under 40 CFR 2, Subpart B.

B.9 Compliance Order Issuance [326 IAC 2-8-5(b)]

IDEM, OAM may issue a compliance order to this Permittee upon discovery that this permit is in nonconformance with an applicable requirement. The order may require immediate compliance or contain a schedule for expeditious compliance with the applicable requirement.

B.10 Compliance with Permit Conditions [326 IAC 2-8-4(5)(A)] [326 IAC 2-8-4(5)(B)]

- (a) The Permittee must comply with all conditions of this permit. Noncompliance with any provisions of this permit, except those specifically designated as not federally enforceable, constitutes a violation of the Clean Air Act and is grounds for:
 - (1) Enforcement action;
 - (2) Permit termination, revocation and reissuance, or modification; and
 - (3) Denial of a permit renewal application.
- (b) It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

B.11 Certification [326 IAC 2-8-3(d)] [326 IAC 2-8-4(3)(C)(i)] [326 IAC 2-8-5(1)]

- (a) Where specifically designated by this permit or required by an applicable requirement, any application form, report, or compliance certification submitted under this permit shall contain certification by a authorized individual of truth, accuracy, and completeness. This certification, shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- (b) One (1) certification shall be included, on the attached Certification Form, with each submittal.
- (c) An authorized individual is defined at 326 IAC 2-1.1-1(1).

B.12 Annual Compliance Certification [326 IAC 2-8-5(a)(1)]

- (a) The Permittee shall annually submit a compliance certification report which addresses the status of the source's compliance with the terms and conditions contained in this permit, including emission limitations, standards, or work practices. The certification shall cover the time period from January 1 to December 31 of the previous year, and shall be submitted in letter form no later than July 1 of each year to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Management
100 North Senate Avenue, P.O. Box 6015
Indianapolis, Indiana 46206-6015

- (b) The annual compliance certification report required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAM, on or before the date it is due.
- (c) The annual compliance certification report shall include the following:
 - (1) The identification of each term or condition of this permit that is the basis of the certification;
 - (2) The compliance status;
 - (3) Whether compliance was based on continuous or intermittent data;
 - (4) The methods used for determining the compliance status of the source, currently and over the reporting period consistent with 326 IAC 2-8-4(3); and
 - (5) Such other facts as specified in Sections D of this permit, IDEM, OAM, may require to determine the compliance status of the source.

The notification which shall be submitted by the Permittee does require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

B.13 Preventive Maintenance Plan [326 IAC 1-6-3][326 IAC 2-8-4(9)] [326 IAC 2-8-5(a)(1)]

- (a) If required by specific condition(s) in Section D of this permit, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMP) within ninety (90) days (this time frame is determined on a case by case basis but no more than ninety (90) days) after issuance of this permit, including the following information on each facility:
 - (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
 - (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions;
 - (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If due to circumstances beyond its control, the PMP cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Management
100 North Senate Avenue, P. O. Box 6015
Indianapolis, Indiana 46206-6015

- (b) The Permittee shall implement the Preventive Maintenance Plans as necessary to ensure that failure to implement the Preventive Maintenance Plan does not cause or contribute to a violation of any limitation on emissions or potential to emit.
- (c) PMP's shall be submitted to IDEM, OAM, upon request and shall be subject to review and approval by IDEM, OAM. IDEM, OAM, may require the Permittee to revise its Preventive Maintenance Plan whenever lack of proper maintenance causes or contributes to any violation.

B.14 Emergency Provisions [326 IAC 2-8-12]

- (a) An emergency, as defined in 326 IAC 2-7-1(12), is not an affirmative defense for an action brought for noncompliance with a federal or state health-based emission limitation, except as provided in 326 IAC 2-8-12.
- (b) An emergency, as defined in 326 IAC 2-7-1(12), constitutes an affirmative defense to an action brought for noncompliance with a health-based or technology-based emission limitation if the affirmative defense of an emergency is demonstrated through properly signed, contemporaneous operating logs or other relevant evidence that describes the following:
 - (1) An emergency occurred and the Permittee can, to the extent possible, identify the causes of the emergency;
 - (2) The permitted facility was at the time being properly operated;
 - (3) During the period of an emergency, the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission standards or other requirements in this permit;
 - (4) For each emergency lasting one (1) hour or more, the Permittee notified IDEM, OAM, within four (4) daytime business hours after the beginning of the emergency, or after the emergency was discovered or reasonably should have been discovered;

Telephone No.: 1-800-451-6027 (ask for Office of Air Management, Compliance Section) or,
Telephone No.: 317-233-5674 (ask for Compliance Section)
Facsimile No.: 317-233-5967

Failure to notify IDEM, OAM, by telephone or facsimile within four (4) daytime business hours after the beginning of the emergency, or after the emergency is discovered or reasonably should have been discovered, shall constitute a violation of 326 IAC 2-8 and any other applicable rules. [326 IAC 2-8-12(f)]

- (5) For each emergency lasting one (1) hour or more, the Permittee submitted notice either in writing or facsimile, of the emergency to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Management
100 North Senate Avenue, P.O. Box 6015
Indianapolis, Indiana 46206-6015

within two (2) working days of the time when emission limitations were exceeded due to the emergency.

The notice fulfills the requirement of 326 IAC 2-8-4(3)(C)(ii) and must contain the following:

- (A) A description of the emergency;
- (B) Any steps taken to mitigate the emissions; and
- (C) Corrective actions taken.

The notification which shall be submitted by the Permittee does not require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (6) The Permittee immediately took all reasonable steps to correct the emergency.
- (c) In any enforcement proceeding, the Permittee seeking to establish the occurrence of an emergency has the burden of proof.
- (d) This emergency provision supersedes 326 IAC 1-6 (Malfunctions) for sources subject to this rule after the effective date of this rule. This permit condition is in addition to any emergency or upset provision contained in any applicable requirement.
- (e) IDEM, OAM, may require that the Preventive Maintenance Plans required under 326 IAC 2-8-3(c)(6) be revised in response to an emergency.
- (f) Failure to notify IDEM, OAM, by telephone or facsimile of an emergency lasting more than one (1) hour in compliance with (b)(4) and (5) of this condition shall constitute a violation of 326 IAC 2-8 and any other applicable rules.
- (g) Operations may continue during an emergency only if the following conditions are met:
 - (1) If the emergency situation causes a deviation from a technology-based limit, the Permittee may continue to operate the affected emitting facilities during the emergency provided the Permittee immediately takes all reasonable steps to correct the emergency and minimize emissions.
 - (2) If an emergency situation causes a deviation from a health-based limit, the Permittee may not continue to operate the affected emissions facilities unless:
 - (A) The Permittee immediately takes all reasonable steps to correct the emergency situation and to minimize emissions; and
 - (B) Continued operation of the facilities is necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw material of substantial economic value.

Any operations shall continue no longer than the minimum time required to prevent the situations identified in (g)(2)(B) of this condition.

B.15 Deviations from Permit Requirements and Conditions [326 IAC 2-8-4(3)(C)(ii)]

- (a) Deviations from any permit requirements (for emergencies see Section B - Emergency Provision), the probable cause of such deviations, and any response steps or preventive measures taken shall be reported to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Management
100 North Senate Avenue, P.O. Box 6015
Indianapolis, Indiana 46206-6015

within ten (10) calendar days from the date of the discovery of the deviation.

- (b) A deviation is an exceedance of a permit limitation or a failure to comply with a requirement of the permit or a rule. It does not include:

- (1) An excursion from compliance monitoring parameters as identified in Section D of this permit unless tied to an applicable rule or limit; or
- (2) An emergency as defined in 326 IAC 2-7-1(12); or
- (3) Failure to implement elements of the Preventive Maintenance Plan unless such failure has caused or contributed to a deviation.
- (4) Failure to make or record information required by the compliance monitoring provisions of Section D unless such failure exceeds 5% of the required data in any calendar quarter.

A Permittee's failure to take the appropriate response step when an excursion of a compliance monitoring parameter has occurred is a deviation.

- (c) Written notification shall be submitted on the attached Emergency/Deviation Occurrence Reporting Form or its substantial equivalent. The notification does not need to be certified by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (d) Proper notice submittal under 326 IAC 2-7-16 satisfies the requirement of this subsection.

B.16 Permit Modification, Reopening, Revocation and Reissuance, or Termination
[326 IAC 2-8-4(5)(C)] [326 IAC 2-8-7(a)] [326 IAC 2-8-8]

- (a) This permit may be modified, reopened, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a FESOP modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any condition of this permit. [326 IAC 2-8-4(5)(C)]
- (b) This permit shall be reopened and revised under any of the circumstances listed in IC 13-15-7-2 or if IDEM, OAM determines any of the following:
 - (1) That this permit contains a material mistake.
 - (2) That inaccurate statements were made in establishing the emissions standards or other terms or conditions.
 - (3) That this permit must be revised or revoked to assure compliance with an applicable requirement. [326 IAC 2-8-8(a)]
- (c) Proceedings by IDEM, OAM, to reopen and revise this permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of this permit for which cause to reopen exists. Such reopening and revision shall be made as expeditiously as practicable. [326 IAC 2-8-8(b)]
- (d) The reopening and revision of this permit, under 326 IAC 2-8-8(a), shall not be initiated before notice of such intent is provided to the Permittee by IDEM, OAM, at least thirty (30) days in advance of the date this permit is to be reopened, except that IDEM, OAM, may provide a shorter time period in the case of an emergency. [326 IAC 2-8-8(c)]

B.17 Permit Renewal [326 IAC 2-8-3(h)]

- (a) The application for renewal shall be submitted using the application form or forms prescribed by IDEM, OAM and shall include the information specified in 326 IAC 2-8-3. Such information shall be included in the application for each emission unit at this source, except those emission units included on the trivial or insignificant activities list contained in 326 IAC 2-7-1(21) and 326 IAC 2-7-1(40).

Request for renewal shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Management
100 North Senate Avenue, P.O. Box 6015
Indianapolis, IN 46206-6015

- (b) Timely Submittal of Permit Renewal [326 IAC 2-8-3]
 - (1) A timely renewal application is one that is:
 - (A) Submitted at least nine (9) months prior to the date of the expiration of this permit; and
 - (B) If the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAM, on or before the date it is due.
 - (2) If IDEM, OAM upon receiving a timely and complete permit application, fails to issue or deny the permit renewal prior to the expiration date of this permit, this existing permit shall not expire and all terms and conditions shall continue in effect until the renewal permit has been issued or denied.
- (c) Right to Operate After Application for Renewal [326 IAC 2-8-9]

If the Permittee submits a timely and complete application for renewal of this permit, the source's failure to have a permit is not a violation of 326 IAC 2-8 until IDEM, OAM takes final action on the renewal application, except that this protection shall cease to apply if, subsequent to the completeness determination, the Permittee fails to submit by the deadline specified in writing by IDEM, OAM, any additional information identified as needed to process the application.

B.18 Permit Amendment or Modification [326 IAC 2-8-10] [326 IAC 2-8-11.1]

- (a) The Permittee must comply with the requirements of 326 IAC 2-8-10 or 326 IAC 2-8-11.1 whenever the Permittee seeks to amend or modify this permit.

- (b) Any application requesting an amendment or modification of this permit shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Management
100 North Senate Avenue, P.O. Box 6015
Indianapolis, Indiana 46206-6015

Any such application should be certified by the "authorized individual" as defined by 326 IAC 2-1.1-1(1) only if a certification is required by the terms of the applicable rule.

- (c) The Permittee may implement the administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-8-10(b)(3)]

B.19 Operational Flexibility [326 IAC 2-8-15]

- (a) The Permittee may make any change or changes at this source that are described in 326 IAC 2-8-15(b) through (d), without prior permit revision, if each of the following conditions is met:

- (1) The changes are not modifications under any provision of Title I of the Clean Air Act;
- (2) Any approval required by 326 IAC 2-1.1 has been obtained;
- (3) The changes do not result in emissions which exceed the emissions allowable under this permit (whether expressed herein as a rate of emissions or in terms of total emissions);
- (4) The Permittee notifies the:

Indiana Department of Environmental Management
Permits Branch, Office of Air Management
100 North Senate Avenue, P.O. Box 6015
Indianapolis, Indiana 46206-6015

and

United States Environmental Protection Agency, Region V
Air and Radiation Division, Regulation Development Branch - Indiana (AR-18J)
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

in advance of the change by written notification at least ten (10) days in advance of the proposed change. The Permittee shall attach every such notice to the Permittee's copy of this permit; and

- (5) The Permittee maintains records on-site which document, on a rolling five (5) year basis, all such changes and emissions trading that are subject to 326 IAC 2-8-15(b) through (d) and makes such records available, upon reasonable request, to public review.

Such records shall consist of all information required to be submitted to IDEM, OAM, in the notices specified in 326 IAC 2-8-15(b), (c)(1), and (d).

- (b) The Permittee may make Section 502(b)(10) of the Clean Air Act changes (this term is defined at 326 IAC 2-7-1(36)) without a permit revision, subject to the constraint of 326 IAC 2-8-15(a) and the following additional conditions:

- (1) A brief description of the change within the source;
- (2) The date on which the change will occur;
- (3) Any change in emissions; and
- (4) Any permit term or condition that is no longer applicable as a result of the change.

The notification which shall be submitted by the Permittee does not require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1.

- (c) Emission Trades [326 IAC 2-8-15(c)]
The Permittee may trade increases and decreases in emissions in the source, where the applicable SIP provides for such emission trades without requiring a permit revision, subject to the constraints of Section (a) of this condition and those in 326 IAC 2-8-15(c).

- (d) Alternative Operating Scenarios [326 IAC 2-8-15(d)]
The Permittee may make changes at the source within the range of alternative operating scenarios that are described in the terms and conditions of this permit in accordance with 326 IAC 2-8-4(7). No prior notification of IDEM, OAM or U.S. EPA is required.
- (e) Backup fuel switches specifically addressed in, and limited under, Section D of this permit shall not be considered alternative operating scenarios. Therefore, the notification requirements of part (a) of this condition do not apply.

B.20 Construction Permit Requirement [326 IAC 2]

A modification, construction, or reconstruction shall be approved if required by and in accordance with the applicable provisions of 326 IAC 2.

B.21 Inspection and Entry [326 IAC 2-8-5(a)(2)]

Upon presentation of proper identification cards, credentials, and other documents as may be required by law, and subject to the Permittee's right under all applicable laws and regulations to assert that the information collected by the agency is confidential and entitled to be treated as such, the Permittee shall allow IDEM, OAM, U.S. EPA, or an authorized representative to perform the following:

- (a) Enter upon the Permittee's premises where a FESOP source is located, or emissions related activity is conducted, or where records must be kept under the conditions of this permit;
- (b) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) Inspect, at reasonable times, any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit;
- (d) Sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with this permit or applicable requirements; and
- (e) Utilize any photographic, recording, testing, monitoring, or other equipment for the purpose of assuring compliance with this permit or applicable requirements.
[326 IAC 2-8-5(a)(4)]

B.22 Transfer of Ownership or Operational Control [326 IAC 2-8-10]

- (a) The Permittee must comply with the requirements of 326 IAC 2-8-10 whenever the Permittee seeks to change the ownership or operational control of the source and no other change in the permit is necessary.
- (b) Any application requesting a change in the ownership or operational control of the source shall contain a written agreement containing a specific date for transfer of permit responsibility, coverage and liability between the current and new Permittee. The application shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Management
100 North Senate Avenue, P.O. Box 6015
Indianapolis, Indiana 46206-6015

The application which shall be submitted by the Permittee does not require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request.
[326 IAC 2-8-11(b)(3)]

B.23 Annual Fee Payment [326 IAC 2-8-4(6)][326 IAC 2-8-16]

- (a) The Permittee shall pay annual fees to IDEM, OAM, within thirty (30) calendar days of receipt of a billing. If the Permittee does not receive a bill from IDEM, OAM the applicable fee is due April 1 of each year.
- (b) Failure to pay may result in administrative enforcement action, or revocation of this permit.
- (c) The Permittee may call the following telephone numbers: 1-800-451-6027 or 317-233-0425 (ask for OAM, Technical Support and Modeling Section), to determine the appropriate permit fee.

SECTION C SOURCE OPERATION CONDITIONS

Entire Source

Emissions Limitations and Standards [326 IAC 2-8-4(1)]

C.1 Overall Source Limit [326 IAC 2-8]

The purpose of this permit is to limit this source's potential to emit to less than major source levels for the purpose of Section 502(a) of the Clean Air Act.

(a) Pursuant to 326 IAC 2-8:

- (1) The potential to emit any regulated pollutant from the entire source shall be limited to less than one-hundred (100) tons per twelve (12) consecutive month period.
- (2) The potential to emit any individual hazardous air pollutant (HAP) from the entire source shall be limited to less than ten (10) tons per twelve (12) consecutive month period; and
- (3) The potential to emit any combination of HAPs from the entire source shall be limited to less than twenty-five (25) tons per twelve (12) consecutive month period.

(b) This condition shall include all emission points at this source including those that are insignificant as defined in 326 IAC 2-7-1(21). The source shall be allowed to add insignificant activities not already listed in this permit, provided that the source's potential to emit does not exceed the above specified limits.

(c) Section D of this permit contains independently enforceable provisions to satisfy this requirement.

C.2 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Exemptions), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings) as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor in a six (6) hour period.

C.3 Open Burning [326 IAC 4-1] [IC 13-17-9]

The Permittee shall not open burn any material except as provided in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6. The previous sentence notwithstanding, the Permittee may open burn in accordance with an open burning approval issued by the Commissioner under 326 IAC 4-1-4.1. 326 IAC 4-1-3(a)(2)(A) and (B) are not federally enforceable.

C.4 Incineration [326 IAC 4-2] [326 IAC 9-1-2(3)]

The Permittee shall not operate an incinerator or incinerate any waste or refuse except as provided in 326 IAC 4-2 and in 326 IAC 9-1-2. The provisions of 326 IAC 9-1-2 are not federally enforceable.

C.5 Fugitive Dust Emissions [326 IAC 6-4]

The Permittee shall not allow fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located, in a manner that would violate 326 IAC 6-4 (Fugitive Dust Emissions). 326 IAC 6-4-2(4) is not federally enforceable.

C.6 Operation of Equipment [326 IAC 2-8-5(a)(4)]

Except as otherwise provided in this permit, all air pollution control equipment listed in this permit and used to comply with an applicable requirement shall be operated at all times that the emission units vented to the control equipment are in operation.

C.7 Stack Height [326 IAC 1-7]

The Permittee shall comply with the applicable provisions of 326 IAC 1-7 (Stack Height Provisions), for all exhaust stacks through which a potential (before controls) of twenty-five (25) tons per year or more of particulate matter or sulfur dioxide is emitted.

C.8 Asbestos Abatement Projects [326 IAC 14-10] [326 IAC 18] [40 CFR 61.140]

- (a) Notification requirements apply to each owner or operator. If the combined amount of regulated asbestos containing material (RACM) to be stripped, removed or disturbed is at least 260 linear feet on pipes or 160 square feet on other facility components, or at least thirty-five (35) cubic feet on all facility components, then the notification requirements of 326 IAC 14-10-3 are mandatory. All demolition projects require notification whether or not asbestos is present.
- (b) The Permittee shall ensure that a written notification is sent on a form provided by the Commissioner at least ten (10) working days before asbestos stripping or removal work or before demolition begins, per 326 IAC 14-10-3, and shall update such notice as necessary, including, but not limited to the following:
 - (1) When the amount of affected asbestos containing material increases or decreases by at least twenty percent (20%); or
 - (2) If there is a change in the following:
 - (A) Asbestos removal or demolition start date;
 - (B) Removal or demolition contractor; or
 - (C) Waste disposal site.
- (c) The Permittee shall ensure that the notice is postmarked or delivered according to the guidelines set forth in 326 IAC 14-10-3(2).
- (d) The notice to be submitted shall include the information enumerated in 326 IAC 14-10-3(3).

All required notifications shall be submitted to:

Indiana Department of Environmental Management
Asbestos Section, Office of Air Management
100 North Senate Avenue, P.O. Box 6015
Indianapolis, Indiana 46206-6015

The notifications do not require a certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (e) **Procedures for Asbestos Emission Control**
The Permittee shall comply with the applicable emission control procedures in 326 IAC 14-10-4 and 40 CFR 61.145(c). Per 326 IAC 14-10-4 emission control requirements are applicable for any removal or disturbance of RACM greater than three (3) linear feet on pipes or three (3) square feet on any other facility components or a total of at least 0.75 cubic feet on all facility components.
- (f) **Indiana Accredited Asbestos Inspector**
The Permittee shall comply with 326 IAC 14-10-1(a) that requires the owner or operator, prior to a renovation/demolition, to use an Indiana Accredited Asbestos Inspector to thoroughly inspect the affected portion of the facility for the presence of asbestos. The requirement that the inspector be accredited is federally enforceable.

Testing Requirements [326 IAC 2-8-4(3)]

C.9 Performance Testing [326 IAC 3-6]

- (a) All testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this permit, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAM.

A test protocol, except as provided elsewhere in this permit, shall be submitted to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Management
100 North Senate Avenue, P.O. Box 6015
Indianapolis, Indiana 46206-6015

no later than thirty-five (35) days prior to the intended test date. The Permittee shall submit a notice of the actual test date to the above address so that it is received at least two weeks prior to the test date.

- (b) All test reports must be received by IDEM, OAM within forty-five (45) days after the completion of the testing. An extension may be granted by the IDEM, OAM, if the source submits to IDEM, OAM, a reasonable written explanation within five (5) days prior to the end of the initial forty-five (45) day period.

The documentation submitted by the Permittee does not require certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

C.10 Compliance Monitoring [326 IAC 2-8-4(3)] [326 IAC 2-8-5(a)(1)]

Compliance with applicable requirements shall be documented as required by this permit. All monitoring and record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance. The Permittee shall be responsible for installing any necessary equipment and initiating any required monitoring related to that equipment. If due to circumstances beyond its control, that equipment cannot be installed and operated within ninety (90) days, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Management
100 North Senate Avenue, P.O. Box 6015
Indianapolis, Indiana 46206-6015

in writing, prior to the end of the initial ninety (90) day compliance schedule with full justification of the reasons for inability to meet this date.

The notification which shall be submitted by the Permittee does require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

C.11 Maintenance of Monitoring Equipment [326 IAC 2-8-4(3)(A)(iii)]

- (a) In the event that a breakdown of the monitoring equipment occurs, a record shall be made of the times and reasons of the breakdown and efforts made to correct the problem. To the extent practicable, supplemental or intermittent monitoring of the parameter should be implemented at intervals no less frequent than required in Section D of this permit until such time as the monitoring equipment is back in operation. In the case of continuous monitoring, supplemental or intermittent monitoring of the parameter should be implemented at intervals no less than one (1) hour (this time frame is determined on a case by case basis) until such time as the continuous monitor is back in operation.
- (b) The Permittee shall install, calibrate, quality assure, maintain, and operate all necessary monitors and related equipment. In addition, prompt corrective action shall be initiated whenever indicated.

C.12 Monitoring Methods [326 IAC 3]

Any monitoring or testing performed required by Section D of this permit shall be performed according to the provisions of 326 IAC 3, 40 CFR 60, Appendix A, or other approved methods as specified in this permit.

Corrective Actions and Response Steps [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

C.13 Emergency Reduction Plans [326 IAC 1-5-2] [326 IAC 1-5-3]

Pursuant to 326 IAC 1-5-2 (Emergency Reduction Plans; Submission):

- (a) The Permittee shall prepare written emergency reduction plans (ERPs) consistent with safe operating procedures.
- (b) These ERPs shall be submitted for approval to:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Management
100 North Senate Avenue, P.O. Box 6015
Indianapolis, Indiana 46206-6015

within ninety (90) days from the date of issuance of this permit.

The ERP does not require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

- (c) If the ERP is disapproved by IDEM, OAM, the Permittee shall have an additional thirty (30) days to resolve the differences and submit an approvable ERP.
- (d) These ERPs shall state those actions that will be taken, when each episode level is declared, to reduce or eliminate emissions of the appropriate air pollutants.
- (e) Said ERPs shall also identify the sources of air pollutants, the approximate amount of reduction of the pollutants, and a brief description of the manner in which the reduction will be achieved.

- (f) Upon direct notification by IDEM, OAM, that a specific air pollution episode level is in effect, the Permittee shall immediately put into effect the actions stipulated in the approved ERP for the appropriate episode level. [326 IAC 1-5-3]

C.14 Risk Management Plan [326 IAC 2-8-4] [40 CFR 68.215]

If a regulated substance, subject to 40 CFR 68, is present at a source in more than a threshold quantity, 40 CFR 68 is an applicable requirement and the Permittee shall:

- (a) Submit:
 - (1) A compliance schedule for meeting the requirements of 40 CFR 68 by the date provided in 40 CFR 68.10(a); or
 - (2) As a part of the compliance certification submitted under 326 IAC 2-7-6(5), a certification statement that the source is in compliance with all the requirements of 40 CFR 68, including the registration and submission of a Risk Management Plan (RMP); and
 - (3) A verification to IDEM, OAM, that a RMP or a revised plan was prepared and submitted as required by 40 CFR 68.
- (b) Provide annual certification to IDEM, OAM, that the Risk Management Plan is being properly implemented.

All documents submitted pursuant to this condition shall include the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

C.15 Compliance Monitoring Plan - Failure to Take Response Steps [326 IAC 2-8-4][326 IAC 2-8-5] [326 IAC 1-6]

- (a) The Permittee is required to implement a compliance monitoring plan to ensure that reasonable information is available to evaluate its continuous compliance with applicable requirements. This compliance monitoring plan is comprised of:
 - (1) This condition;
 - (2) The Compliance Determination Requirements in Section D of this permit;
 - (3) The Compliance Monitoring Requirements in Section D of this permit;
 - (4) The Record Keeping and Reporting Requirements in Section C (Monitoring Data Availability, General Record Keeping Requirements, and General Reporting Requirements) and in Section D of this permit; and
 - (5) A Compliance Response Plan (CRP) for each compliance monitoring condition of this permit. CRP's shall be submitted to IDEM, OAM upon request and shall be subject to review and approval by IDEM, OAM. The CRP shall be prepared within ninety (90) days after issuance of this permit by the Permittee and maintained on site, and is comprised of :
 - (A) Response steps that will be implemented in the event that compliance related information indicates that a response step is needed pursuant to the requirements of Section D of this permit; and

- (B) A time schedule for taking such response steps including a schedule for devising additional response steps for situations that may not have been predicted.
- (b) For each compliance monitoring condition of this permit, appropriate response steps shall be taken when indicated by the provisions of that compliance monitoring condition. Failure to perform the actions detailed in the compliance monitoring conditions or failure to take the response steps within the time prescribed in the Compliance Response Plan, shall constitute a violation of the permit unless taking the response steps set forth in the Compliance Response Plan would be unreasonable.
- (c) After investigating the reason for the excursion, the Permittee is excused from taking further response steps for any of the following reasons:
 - (1) The monitoring equipment malfunctioned, giving a false reading. This shall be an excuse from taking further response steps providing that prompt action was taken to correct the monitoring equipment.
 - (2) The Permittee has determined that the compliance monitoring parameters established in the permit conditions are technically inappropriate, has previously submitted a request for an administrative amendment to the permit, and such request has not been denied or;
 - (3) An automatic measurement was taken when the process was not operating; or
 - (4) The process has already returned to operating within "normal" parameters and no response steps are required.
- (d) Records shall be kept of all instances in which the compliance related information was not met and of all response steps taken. In the event of an emergency, the provisions of 326 IAC 2-7-16 (Emergency Provisions) requiring prompt corrective action to mitigate emissions shall prevail.

C.16 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-8-4]
[326 IAC 2-8-5]

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this permit exceed the level specified in any condition of this permit, the Permittee shall take appropriate corrective actions. The Permittee shall submit a description of these corrective actions to IDEM, OAM, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize emissions from the affected facility while the corrective actions are being implemented. IDEM, OAM shall notify the Permittee within thirty (30) days, if the corrective actions taken are deficient. The Permittee shall submit a description of additional corrective actions taken to IDEM, OAM within thirty (30) days of receipt of the notice of deficiency. IDEM, OAM reserves the authority to use enforcement activities to resolve noncompliant stack tests.
- (b) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to IDEM, OAM that retesting in one-hundred and twenty (120) days is not practicable, IDEM, OAM may extend the retesting deadline. Failure of the second test to demonstrate compliance with the appropriate permit conditions may be grounds for immediate revocation of the permit to operate the affected facility.

The documents submitted pursuant to this condition do not require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)]

C.17 Monitoring Data Availability

- (a) With the exception of performance tests conducted in accordance with Section C-Performance Testing all observations, sampling, maintenance procedures, and record keeping, required as a condition of this permit shall be performed at all times the equipment is operating at normal representative conditions.
- (b) As an alternative to the observations, sampling, maintenance procedures, and record keeping of subsection (a) above, when the equipment listed in Section D of this permit is not operating, the Permittee shall either record the fact that the equipment is shut down or perform the observations, sampling, maintenance procedures, and record keeping that would otherwise be required by this permit.
- (c) If the equipment is operating but abnormal conditions prevail, additional observations and sampling should be taken with a record made of the nature of the abnormality.
- (d) If for reasons beyond its control, the operator fails to make required observations, sampling, maintenance procedures, or record keeping, reasons for this must be recorded.
- (e) At its discretion, IDEM may excuse such failure providing adequate justification is documented and such failures do not exceed five percent (5%) of the operating time in any quarter.
- (f) Temporary, unscheduled unavailability of staff qualified to perform the required observations, sampling, maintenance procedures, or record keeping shall be considered a valid reason for failure to perform the requirements in (a) above.

C.18 General Record Keeping Requirements [326 IAC 2-8-4(3)][326 IAC 2-8-5]

- (a) Records of all required monitoring data and support information shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be kept at the source location for a minimum of three (3) years and available upon the request of an IDEM, OAM, representative. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a written request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.
- (b) Records of required monitoring information shall include, where applicable:
 - (1) The date, place, and time of sampling or measurements;
 - (2) The dates analyses were performed;
 - (3) The company or entity performing the analyses;
 - (4) The analytic techniques or methods used;
 - (5) The results of such analyses; and
 - (6) The operating conditions existing at the time of sampling or measurement.

- (c) Support information shall include, where applicable:
 - (1) Copies of all reports required by this permit;
 - (2) All original strip chart recordings for continuous monitoring instrumentation;
 - (3) All calibration and maintenance records;
 - (4) Records of preventive maintenance shall be sufficient to demonstrate that failure to implement the Preventive Maintenance Plan did not cause or contribute to a violation of any limitation on emissions or potential to emit. To be relied upon subsequent to any such violation, these records may include, but are not limited to: work orders, parts inventories, and operator's standard operating procedures. Records of response steps taken shall indicate whether the response steps were performed in accordance with the Compliance Response Plan required by Section C - Compliance Monitoring Plan - Failure to take Response Steps, of this permit, and whether a deviation from a permit condition was reported. All records shall briefly describe what maintenance and response steps were taken and indicate who performed the tasks.
- (d) All record keeping requirements not already legally required shall be implemented within ninety (90) days of permit issuance.

C.19 General Reporting Requirements [326 IAC 2-8-4(3)(C)]

- (a) To affirm that the source has met all the compliance monitoring requirements stated in this permit the source shall submit a Quarterly Compliance Monitoring Report. Any deviation from the requirements and the date(s) of each deviation must be reported. The Compliance Monitoring Report shall include the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (b) The report required in (a) of this condition and reports required by conditions in Section D of this permit shall be submitted to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Management
100 North Senate Avenue, P. O. Box 6015
Indianapolis, Indiana 46206-6015
- (c) Unless otherwise specified in this permit, any notice, report, or other submission required by this permit shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAM, on or before the date it is due.
- (d) Unless otherwise specified in this permit, any quarterly report shall be submitted within thirty (30) days of the end of the reporting period. The report does not require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (e) All instances of deviations as described in Section B- Deviations from Permit Requirements Conditions must be clearly identified in such reports. The Emergency/Deviation Occurrence Report does not require the certification by the "authorized individual" as defined by 326 IAC 2-1.1-1(1).
- (f) Any corrective actions or response steps taken as a result of each deviation must be clearly identified in such reports.

- (g) The first report shall cover the period commencing on the date of issuance of this permit and ending on the last day of the reporting period.

Stratospheric Ozone Protection

C.20 Compliance with 40 CFR 82 and 326 IAC 22-1

Pursuant to 40 CFR 82 (Protection of Stratospheric Ozone), Subpart F, except as provided for motor vehicle air conditioners in Subpart B, the Permittee shall comply with the standards for recycling and emissions reduction:

- (a) Persons opening appliances for maintenance, service, repair or disposal must comply with the required practices pursuant to 40 CFR 82.156
- (b) Equipment used during the maintenance, service, repair or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
- (c) Persons performing maintenance, service, repair or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.

SECTION D.1 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-8-4(10)]:

- (a) One (1) natural gas fired boiler (using no. 2 fuel oil as backup, with a maximum sulfur content of 0.5%), identified as Boiler 1, with a maximum heat input rate of 67.5 million (MM) British thermal units (Btu) per hour, and exhausting through stack 1; and
- (b) One (1) natural gas fired boiler (using no. 2 fuel oil as backup, with a maximum sulfur content of 0.5%), identified as Boiler 2, with a maximum heat input rate of 45.7 MMBtu per hour, and exhausting through stack 2.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-8-4(1)]

D.1.1 Particulate Matter Limitation (PM) [326 IAC 6-2-4]

Pursuant to 326 IAC 6-2-4 (Particulate Emission Limitations for Sources of Indirect Heating), particulate matter (PM) from the two (2) natural gas-fired boilers (Boiler 1 and Boiler 2) shall be limited by the following:

$$Pt = 1.09/Q^{0.26}$$

where: Pt = maximum allowable particulate matter (PM) emitted per MMBtu heat input
Q = total source max. indirect heater input = Boiler 1 + Boiler 2 = 67.5 + 45.7 = 113.2 MMBtu/hr

$$Pt = 1.09/113.2^{0.26} = 0.32 \text{ lbs PM/MMBtu}$$

Therefore, the boiler is limited to 0.32 lbs PM/MMBtu

D.1.2 FESOP Limit [326 IAC 2-8]

Pursuant to 326 IAC 2-8 the total usage of # 2 fuel oil for the two (2) boilers (Boiler 1 and Boiler 2) shall be limited to 232,390 gallons per month. This will limit source wide SO₂ emissions to less than 100 tons per year. Therefore, the requirements of 326 IAC 2-7 do not apply.

D.1.3 Sulfur Dioxide (SO₂) [326 IAC 7-1.1-1] [326 IAC 12-1]

Pursuant to 326 IAC 7-1.1 (SO₂ Emissions Limitations) and 40 CFR 60, Subpart Dc (Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units):

- (a) The SO₂ emissions from the 45.7 MMBtu per hour oil-fueled boiler shall not exceed five tenths (0.5) pounds per million Btu heat input; or
- (b) The sulfur content of the fuel oil shall not exceed five-tenths percent (0.5%) by weight. [40 CFR 60.42c(d)]

Pursuant to 40 CFR 60 Subpart Dc, the fuel oil sulfur content limit applies at all times, including periods of startup, shutdown, and malfunction.

D.1.4 Preventive Maintenance Plan [326 IAC 2-8-4(9)]

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for Boiler 1 and Boiler 2.

Compliance Determination Requirements

D.1.5 Testing Requirements [326 IAC 2-8-5(a)(1), (4)][326 IAC 2-1.1-11]

The Permittee is not required to test this facility by this permit. However, IDEM may require compliance testing when necessary to determine if the facility is in compliance. If testing is required by IDEM, compliance with the PM limit specified in Condition D.1.1 shall be determined by a performance test conducted in accordance with Section C - Performance Testing.

D.1.6 Sulfur Dioxide Emissions and Sulfur Content

Pursuant to 40 CFR 60, Subpart Dc, the Permittee shall demonstrate compliance utilizing one of the following options:

- (a) Providing vendor analysis of fuel delivered, if accompanied by a certification; or
- (b) Analyzing the oil sample to determine the sulfur content of the oil via the procedures in 40 CFR 60, Appendix A, Method 19.
 - (1) Oil samples may be collected from the fuel tank immediately after the fuel tank is filled and before any oil is combusted; and
 - (2) If a partially empty fuel tank is refilled, a new sample and analysis would be required upon filling.

Compliance Monitoring Requirements [326 IAC 2-8-4] [326 IAC 2-8-5(a)(1)]

D.1.7 Visible Emissions Notations

- (a) Visible emission notations of the Boiler 1 and Boiler 2 stack exhausts shall be performed once per shift during normal daylight operations when exhausting to the atmosphere. A trained employee shall record whether emissions are normal or abnormal.
- (b) For processes operated continuously, "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time.
- (c) In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions.
- (d) A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process.
- (e) The Compliance Response Plan for this unit shall contain troubleshooting contingency and response steps for when an abnormal emission is observed.

Record Keeping and Reporting Requirements [326 IAC 2-8-4(3)] [326 IAC 2-8-16]

D.1.8 Record Keeping Requirements

- (a) To document compliance with Condition D.1.2, the Permittee shall maintain records in accordance with (1) through (6) below. Note that pursuant to 40 CFR 60 Subpart Dc, the fuel oil sulfur limit applies at all times including periods of startup, shutdown, and malfunction.
 - (1) Actual fuel oil usage since last compliance determination period;

- (2) A certification, signed by the owner or operator, that the records of the fuel supplier certifications represent all of the fuel combusted during the period; and

If the fuel supplier certification is used to demonstrate compliance the following, as a minimum, shall be maintained:

- (3) Fuel supplier certifications.
- (4) The name of the fuel supplier; and
- (5) A statement from the fuel supplier that certifies the sulfur content of the fuel oil.

The Permittee shall retain records of all recording/monitoring data and support information for a period of five (5) years, or longer if specified elsewhere in this permit, from the date of the monitoring sample, measurement, or report. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit.

- (b) To document compliance with Condition D.1.6, the Permittee shall maintain records of visible emission notations of the Boiler 1 and Boiler 2 stack exhausts once per shift.
- (c) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

D.1.9 Reporting Requirements

A quarterly summary of the information to document compliance with Condition D.1.2 in any compliance period when No. 2 fuel oil was combusted, and the natural gas fired boiler certification, shall be submitted to the address listed in Section C - General Reporting Requirements, using the reporting forms located at the end of this permit, or their equivalent, within thirty (30) days after the end of the quarter being reported.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR MANAGEMENT
COMPLIANCE DATA SECTION**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)
CERTIFICATION**

Source Name: Hartford City Paper, L.L.C.
Source Address: 501 South Spring, Hartford City, IN 47348
Mailing Address: P.O. Box 30, Hartford City, IN 47348
FESOP No.: F009-7409-00016

This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this permit.

Please check what document is being certified:

- ☐ Annual Compliance Certification Letter
- ☐ Test Result (specify) _____
- ☐ Report (specify) _____
- ☐ Notification (specify) _____
- ☐ Other (specify) _____

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Date:

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR MANAGEMENT
COMPLIANCE DATA SECTION
P.O. Box 6015
100 North Senate Avenue
Indianapolis, Indiana 46206-6015
Phone: 317-233-5674
Fax: 317-233-5967**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)
EMERGENCY/DEVIATION OCCURRENCE REPORT**

Source Name: Hartford City Paper, L.L.C.
Source Address: 501 South Spring, Hartford City, IN 47348
Mailing Address: P.O. Box 30, Hartford City, IN 47348
FESOP No.: F009-7409-00016

This form consists of 2 pages

Page 1 of 2

Check either No. 1 or No.2

- 9** 1. This is an emergency as defined in 326 IAC 2-7-1(12)
CThe Permittee must notify the Office of Air Management (OAM), within four (4) business hours (1-800-451-6027 or 317-233-5674, ask for Compliance Section); and
CThe Permittee must submit notice in writing or by facsimile within two (2) days (Facsimile Number: 317-233-5967), and follow the other requirements of 326 IAC 2-7-16
- 9** 2. This is a deviation, reportable per 326 IAC 2-8-4(3)(C)
CThe Permittee must submit notice in writing within ten (10) calendar days

If any of the following are not applicable, mark N/A

Facility/Equipment/Operation:

Control Equipment:

Permit Condition or Operation Limitation in Permit:

Description of the Emergency/Deviation:

Describe the cause of the Emergency/Deviation:

If any of the following are not applicable, mark N/A

Page 2 of 2

Date/Time Emergency/Deviation started:
Date/Time Emergency/Deviation was corrected:
Was the facility being properly operated at the time of the emergency/deviation? Y N Describe:
Type of Pollutants Emitted: TSP, PM-10, SO ₂ , VOC, NO _x , CO, Pb, other:
Estimated amount of pollutant(s) emitted during emergency/deviation:
Describe the steps taken to mitigate the problem:
Describe the corrective actions/response steps taken:
Describe the measures taken to minimize emissions:
If applicable, describe the reasons why continued operation of the facilities are necessary to prevent imminent injury to persons, severe damage to equipment, substantial loss of capital investment, or loss of product or raw materials of substantial economic value:

Form Completed by: _____
Title / Position: _____
Date: _____
Phone: _____

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR MANAGEMENT
COMPLIANCE DATA SECTION**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)
NATURAL GAS FIRED BOILER CERTIFICATION**

Source Name: Hartford City Paper, L.L.C.
Source Address: 501 South Spring, Hartford City, IN 47348
Mailing Address: P.O. Box 30, Hartford City, IN 47348
FESOP No.: F009-7409-00016

**This certification shall be included when submitting monitoring, testing reports/results
or other documents as required by this permit.**

Report period

Beginning: _____

Ending: _____

Boiler Affected

Alternate Fuel

Days burning alternate fuel

From

To

(can omit boiler affected if only one gas boiler at this plant)

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature: _____

Printed Name: _____

Title/Position: _____

Date: _____

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR MANAGEMENT
COMPLIANCE DATA SECTION**

FESOP Quarterly Report

Source Name: Hartford City Paper, L.L.C.
Source Address: 501 South Spring, Hartford City, IN 47348
Mailing Address: P.O. Box 30, Hartford City, 47348
FESOP No.: F009-7409-00016
Facility: Boiler 1 and Boiler 2
Parameter: No. 2 fuel oil usage
Limit: The input of No. 2 fuel oil to Boiler 1 and Boiler 2 shall not exceed 232,390 gallons per month.

YEAR: _____

Month	# 2 fuel oil usage
Month 1	
Month 2	
Month 3	

9 No deviation occurred in this quarter.

9 Deviation/s occurred in this quarter.

Deviation has been reported on: _____

Submitted by: _____

Title / Position: _____

Signature: _____

Date: _____

Phone: _____

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR MANAGEMENT
COMPLIANCE DATA SECTION**

**FEDERALLY ENFORCEABLE STATE OPERATING PERMIT (FESOP)
QUARTERLY COMPLIANCE MONITORING REPORT**

Source Name: Hartford City Paper, L.L.C.
Source Address: 501 South Spring, Hartford City, IN 47348
Mailing Address: P.O. Box 30, Hartford City, IN 47348
FESOP No.: F009-7409-00016

Months: _____ **to** _____ **Year:** _____

This report is an affirmation that the source has met all the compliance monitoring requirements stated in this permit. This report shall be submitted quarterly. Any deviation from the compliance monitoring requirements and the date(s) of each deviation must be reported. Additional pages may be attached if necessary. This form can be supplemented by attaching the Emergency/Deviation Occurrence Report. If no deviations occurred, please specify in the box marked "No deviations occurred this reporting period".

9 NO DEVIATIONS OCCURRED THIS REPORTING PERIOD.

9 THE FOLLOWING DEVIATIONS OCCURRED THIS REPORTING PERIOD.

Compliance Monitoring Requirement (eg. Permit Condition D.1.3)	Number of Deviations	Date of each Deviation

Form Completed By: _____
Title/Position: _____
Date: _____
Phone: _____

Attach a signed certification to complete this report.

Indiana Department of Environmental Management Office of Air Management

Technical Support Document (TSD) for a Federally Enforceable Operating Permit (FESOP)

Source Background and Description

Source Name: Hartford City Paper, L.L.C
Source Location: 501 South Spring, Hartford City, IN 47348
County: Blackford
SIC Code: 2631
Operation Permit No.: F009-7409-00016
Permit Reviewer: Nishat Hydari / EVP

The Office of Air Management (OAM) has reviewed a FESOP application from Hartford City Paper, L.L.C. relating to the operation of two (2) natural gas-fired boilers using no. 2 fuel oil as backup.

Permitted Emission Units and Pollution Control Equipment

The source consists of the following permitted emission units and pollution control devices:

- (a) One (1) natural gas fired boiler (using no. 2 fuel oil as backup, with a maximum sulfur content of 0.5%), identified as Boiler 1, with a maximum heat input rate of 67.5 million (MM) British thermal units (Btu) per hour, and exhausting through stack 1; and
- (b) One (1) natural gas fired boiler (using no. 2 fuel oil as backup, with a maximum sulfur content of 0.5%), identified as Boiler 2, with a maximum heat input rate of 45.7 MMBtu per hour, and exhausting through stack 2.

Unpermitted Emission Units and Pollution Control Equipment

There are no unpermitted facilities operating at this source during this review process.

Insignificant Activities

This source does not currently have any insignificant activities, as defined in 326 IAC 2-7-1(21).

Existing Approvals

The source has been operating under previous approvals including, but not limited to, the following:

- (a) OP and CP 009-1879-00016, issued on October 23, 1991.

All conditions from previous approvals were incorporated into this FESOP except for operating condition no. 5 which have been revised as follows:

5. That the amount of No. 2 oil burned in the two boilers combined shall be limited to ~~577,994~~ **232,390** gallons per month based on 0.5% sulfur content oil by weight.

Stack Summary

Stack ID	Operation	Height (feet)	Diameter (feet)	Flow Rate (acfm)	Temperature (°F)
1	Boiler 1	50	3.5	18,942	375
2	Boiler 2	50	3.5	23,140	340

Enforcement Issue

This source submitted an operation permit renewal application on December 9, 1996. Upon review of this application, it was determined that the source should have had a FESOP. An enforcement referral is being included with this draft permit.

Recommendation

The staff recommends to the Commissioner that the FESOP be approved. This recommendation is based on the following facts and conditions:

Unless otherwise stated, information used in this review was derived from the application and additional information submitted by the applicant.

An administratively complete application for the purposes of this review was received on December 9, 1996.

Emission Calculations

See Appendix A of this document for detailed emissions calculations (Appendix A, pages 1 through 3).

Potential To Emit

Pursuant to 326 IAC 2-1.1-1(16), Potential to Emit is defined as “the maximum capacity of a stationary source to emit any air pollutant under its physical and operational design. Any physical or operational limitation on the capacity of a source to emit an air pollutant, including air pollution control equipment and restrictions on hours of operation or type or amount of material combusted, stored, or processed shall be treated as part of its design if the limitation is enforceable by the U. S. EPA.”

Pollutant	Potential To Emit (tons/year)
PM	7.08
PM-10	3.77
SO ₂	251.45
VOC	2.73
CO	41.65
NO _x	85.00

Note: For the purpose of determining Title V applicability for particulates, PM-10, not PM, is the regulated pollutant in consideration.

HAP's	Potential To Emit (tons/year)
Acetaldehyde	0.0001
Acrolein	0.0001
Benzene	0.0014
1,3 - Butadiene	0.005
Chlorobenzene	0.0001
Formaldehyde	0.02
Hydrochloric acid	0.12
Toluene	0.0014
Xylenes	0.0005
Arsenic Compounds	0.0002
Beryllium Compounds	0.0001
Cadmium Compounds	0.0005
Chromium Compounds	0.003
Lead Compounds	0.0004
Manganese Compounds	0.0006
Mercury Compounds	0.0001
Nickel Compounds	0.008
Polycyclic Organic Matter	0.001
Selenium Compounds	0.001
TOTAL	0.1635

- (a) The potential to emit (as defined in 326 IAC 2-1.1-1(16)) of SO₂ is equal to or greater than 100 tons per year. Therefore, the source is subject to the provisions of 326 IAC 2-7.
- (b) Fugitive Emissions
Since this type of operation is not one of the twenty-eight (28) listed source categories under 326 IAC 2-2 and since there are no applicable New Source Performance Standards that were in effect on August 7, 1980, the fugitive particulate matter (PM) and volatile organic compound (VOC) emissions are not counted toward determination of PSD and Emission Offset applicability.

Actual Emissions

No previous emission data has been received from the source.

Limited Potential to Emit

The table below summarizes the total potential to emit, reflecting all limits, of the significant emission units.

Process/facility	Limited Potential to Emit (tons/year)							
	PM	PM-10	SO ₂	VOC	CO	NO _x	Single HAP	HAPs
Natural gas combustion (Boiler 1 + Boiler 2)	0.94	3.77	0.30	2.73	41.65	49.58	0.00	0.00
# 2 Fuel oil combustion (Boiler 1 + Boiler 2)	2.79	0.00	99	0.28	6.97	33.46	0.12	0.16
Total Emissions	2.79	3.77	99	2.73	41.65	49.58	0.12	0.16

County Attainment Status

The source is located in Blackford County.

Pollutant	Status
PM-10	attainment
SO ₂	attainment
NO ₂	attainment
Ozone	attainment
CO	attainment
Lead	attainment

- (a) Volatile organic compounds (VOC) and oxides of nitrogen (NO_x) are precursors for the formation of ozone. Therefore, VOC and NO_x emissions are considered when evaluating the rule applicability relating to the ozone standards. Blackford County has been designated as attainment or unclassifiable for ozone.

Federal Rule Applicability

- (a) The 45.7 MMBtu per hour boiler, identified as Boiler 2 is subject to the New Source Performance Standard, 326 IAC 12, (40 CFR 60.40c, Subpart Dc). This rule requires the following:
- (1) SO₂ emissions be limited to 0.5 pounds per MMBtu of heat input during distillate oil firing or distillate oil sulfur content be limited to 0.5 percent by weight at all times including periods of start-up, shut-down and malfunction. The boiler is in compliance with this limitation based on supporting calculations (see Appendix A for supporting calculations);
 - (2) opacity be limited to 20 percent as a 6-minute average, except for one 6-minute period per hour limited to 27 percent opacity, and except for start-up, shut-down and malfunction periods;
 - (3) initial compliance testing for opacity and SO₂ when firing No. 2 distillate fuel oil;
 - (4) SO₂ emissions monitoring, unless the affected facility is subject to the SO₂ emissions standard of §60.42c(h) (1), (2), or (3); and
 - (5) record keeping and reporting as required by Subpart Dc, including quarterly reporting of fuel supplier certification information, fuel oil sulfur content by weight, and the calculated sulfur dioxide emission rate.
- (b) The 67.5 MMBtu per hour boiler, identified as Boiler 1, is not subject to the New Source Performance Standard, 326 IAC 12, (40 CFR 60.40c, Subpart Dc) because it was constructed prior to June 9, 1989.
- (c) There are no National Emission Standards for Hazardous Air Pollutants (NESHAPs)(326 IAC 14 and 40 CFR Part 63) applicable to this source.

State Rule Applicability - Entire Source

326 IAC 2-6 (Emission Reporting)

This source is not subject to 326 IAC 2-6 (Emission Reporting), because it limits the potential to emit SO₂ to less than one hundred (100) tons per year.

326 IAC 2-8-4 (FESOP)

This source is subject to 326 IAC 2-8-4 (FESOP). Pursuant to this rule, the total usage of # 2 fuel oil for the two (2) boilers (Boiler 1 and Boiler 2) shall be limited to 232,390 gallons per month. This will limit source wide SO₂ emissions to less than 100 tons per year. Therefore, the requirements of 326 IAC 2-7 do not apply.

326 IAC 5-1 (Visible Emissions Limitations)

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Exemptions), opacity shall meet the following, unless otherwise stated in this permit:

- (a) Opacity shall not exceed an average of forty percent (40%) any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings) as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

326 IAC 7-1.1 (Sulfur Dioxide Emission Limitations)

The two (2) natural gas-fired boilers using no. 2 fuel oil as back-up fuel are subject to 326 IAC 7-1.1 (Sulfur Dioxide Emission Limitations). Pursuant to 326 IAC 7-1.1-2, sulfur dioxide emissions from the two (2) boilers using No. 2 fuel oil shall be limited to 0.5 pounds per million BTU heat input when using No. 2 fuel oil. This equates to a fuel oil sulfur content limit of 0.5%.

326 IAC 7-2-1 (Sulfur Dioxide Reporting Requirements)

Pursuant to this rule, the source shall submit reports of calendar month average sulfur content, heat content, fuel consumption, and sulfur dioxide emission rate (pounds SO₂ per MMBtu), to the OAM upon request.

State Rule Applicability - Individual Facilities

326 IAC 6-2-4 (Particulate Emission Limitations for Sources of Indirect Heating)

The two (2) natural gas fired boilers (Boiler 1 and Boiler 2) using no. 2 fuel oil as backup, rated at 67.5 and 45.7 MMBtu per hour, respectively, are subject to the particulate matter limitations of 326 IAC 6-2. Pursuant to this rule, the boilers are limited by the following equation from 326 IAC 6-2-4:

$$Pt = 1.09/Q^{0.26}$$

where: Pt = maximum allowable particulate matter (PM) emitted per MMBtu heat input
Q = total source max. indirect heater input = Boiler 1 + Boiler 2 = 67.5 + 45.7 = 113.2 MMBtu/hr

$$Pt = 1.09/113.2^{0.26} = 0.32 \text{ lbs PM/MMBtu}$$

Therefore, the PM emissions from the two (2) boilers is limited to 0.32 lbs PM/MMBtu

Compliance calculation:

$$(0.94 \text{ tons PM/yr}) * (\text{hr}/113.2 \text{ MMBtu}) * (\text{yr}/8,760 \text{ hrs}) * (2,000 \text{ lbs/ton}) = 1.90\text{E-}3 \text{ lbs PM/MMBtu}$$

Actual lbs PM/MMBtu (1.90E-3) is less than allowable lbs PM/MMBtu (0.32), therefore the boilers will comply with the requirements of 326 IAC 6-4.

Compliance Requirements

Permits issued under 326 IAC 2-8 are required to ensure that sources can demonstrate compliance with applicable state and federal rules on a more or less continuous basis. All state and federal rules contain compliance provisions, however, these provisions do not always fulfill the requirement for a more or less continuous demonstration. When this occurs IDEM, OAM, in conjunction with the source, must develop specific conditions to satisfy 326 IAC 2-8-4. As a result, compliance requirements are divided into two sections: Compliance Determination Requirements and Compliance Monitoring Requirements.

Compliance Determination Requirements in Section D of the permit are those conditions that are found more or less directly within state and federal rules and the violation of which serves as grounds for enforcement action. If these conditions are not sufficient to demonstrate continuous compliance, they will be supplemented with Compliance Monitoring Requirements, also Section D of the permit. Unlike Compliance Determination Requirements, failure to meet Compliance Monitoring conditions would serve as a trigger for corrective actions and not grounds for enforcement action. However, a violation in relation to a compliance monitoring condition will arise through a source's failure to take the appropriate corrective actions within a specific time period.

The compliance monitoring requirements applicable to this source are as follows:

1. The two (2) boilers (Boiler 1 and Boiler 2) have applicable compliance monitoring conditions as specified below:
 - (a) Daily visible emissions notations of the boiler stack exhausts (1 and 2) shall be performed during normal daylight operations. A trained employee will record whether emissions are normal or abnormal. For processes operated continuously "normal" means those conditions prevailing, or expected to prevail, eighty percent (80%) of the time the process is in operation, not counting startup or shut down time. In the case of batch or discontinuous operations, readings shall be taken during that part of the operation that would normally be expected to cause the greatest emissions. A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process. The Preventive Maintenance Plan for this unit shall contain troubleshooting contingency and corrective actions for when an abnormal emission is observed.

These monitoring conditions are necessary because the two (2) boilers (Boiler 1 and Boiler 2) must operate properly to ensure compliance with 326 IAC 6-2-4 (Particulate Emission Limitations for Sources of Indirect Heating) and 326 IAC 2-8 (FESOP).

Air Toxic Emissions

Indiana presently requests applicants to provide information on emissions of the 188 hazardous air pollutants (HAPs) set out in the Clean Air Act Amendments of 1990. These pollutants are either carcinogenic or otherwise considered toxic and are commonly used by industries. They are listed as air toxics on the Office of Air Management (OAM) FESOP Application Form GSD-08.

- (a) This source will emit levels of air toxics less than those which constitute a major source according to Section 112 of the 1990 Clean Air Act Amendments.

Conclusion

The operation of these two (2) boilers shall be subject to the conditions of the attached proposed **FESOP No.: F009-7409-00016.**

**Indiana Department of Environmental Management
Office of Air Management**

Addendum to the
Technical Support Document for Federally Enforceable State Operating
Permit (FESOP)

Source Name: Hartford City Paper, L.L.C.
Source Location: 501 South Spring, Hartford City, IN 47348
SIC Code: 2631
County: Blackford
Operation Permit No.: F009-7409-00016
Permit Reviewer: Nishat Hydari/EVP

On April 7, 2000, the Office of Air Management (OAM) had a notice published in the News Times, Hartford City, Indiana, stating that Hartford City Paper, L.L.C. had applied for a Federally Enforceable State Operating Permit (FESOP) to operate two (2) natural gas-fired boilers using no. 2 fuel oil as backup. The notice also stated that OAM proposed to issue a FESOP for this operation and provided information on how the public could review the proposed FESOP and other documentation. Finally, the notice informed interested parties that there was a period of thirty (30) days to provide comments on whether or not this FESOP should be issued as proposed.

Neil Burchard, EHS Manager at Hartford City Paper, L.L.C. submitted comments on the proposed FESOP. The summary of the comments and corresponding responses is as follows:

Comment # 1

Section D.1.3 Preventive Maintenance Plan: There is no pollution control equipment on either Boiler 1 or Boiler 2. The only thing that could be maintained at this time is the boiler tuning for efficiency. Would this be considered to meet the PM plan for these boilers? If so this should be spelled out.

Response # 1

Proper maintenance of oil burners is necessary to prevent excess smoking and potential violations of opacity and particulate matter emission limitations. Most permittees already have a plan for conducting preventive maintenance for the emission units and control devices. It is simply a good business practice to have identified the specific personnel whose job duties include inspecting, maintaining and repairing the emission control devices. The emission unit equipment and the emission control equipment may be covered by a written recommendation from the manufacturer set out schedules for the regular inspection and maintenance of the equipment. The permittee will usually have adopted an inspection and maintenance schedule that works for its particular equipment and process in order to keep equipment downtime to a minimum and achieve environmental compliance. The manufacturer may also have indicated, or the permittee may know from experience, what replacement parts should be kept on hand. The permittee may already keep sufficient spare parts on hand so that if a replacement is needed, it can be quickly installed, without a delay in the permittee's business activities and without an environmental violation. For the most part, the PMP can be created by combining present business practices and equipment manufacturer guidance into one document, the Preventive Maintenance Plan (PMP).

The permittee has 90 days to prepare, maintain and implement the PMP. IDEM is not going to draft the PMP. Permittees know their processes and equipment extremely well and are in the best position to draft the PMP. IDEM's air inspectors and permit staff will be available to assist the permittee with any questions about the PMP. IDEM may request a copy of the PMP to review and approve.

The Preventive Maintenance Plan requirement must be included in every applicable FESOP permit pursuant to 326 IAC 2-8-4(9). Both of those rules refer back to the Preventive Maintenance Plan requirement as described in 326 IAC 1-6-3. This Preventive Maintenance Plan rule sets out the requirements for:

- (1) Identification of the individuals responsible for inspecting, maintaining and repairing the emission control equipment (326 IAC 1-6-3(a)(1)),
- (2) The description of the items or conditions in the facility that will be inspected and the inspection schedule for said items or conditions (326 IAC 1-6-3(a)(2)), and
- (3) The identification and quantification of the replacement parts for the facility which the permittee will maintain in inventory for quick replacement (326 IAC 1-6-3(a)(2)).

It is clear from the structure of the wording in 326 IAC 1-6-3 that the PMP requirement affects the entirety of the applicable facilities. Only 326 IAC 1-6-3(a)(1) is limited, in that it requires identification of the personnel in charge of only the emission control equipment, and not any other facility equipment. The commissioner may require changes in the maintenance plan to reduce excessive malfunctions in any control device or combustion or process equipment under 326 IAC 1-6-5. No changes have been made to the permit as a result of this comment.

Comment # 2

Section C.7 A building houses the paper-processing machine that is adjacent to the boiler house. This building is approximately 20 feet taller than the stacks on the boilers. The building is 70 ft from the boiler house stacks and is 120 ft wide. These numbers are approximate. The question is are the boiler stacks high enough to fit the FESOP rule?

Response # 2

326 IAC 1-7-5(a), states "all sources having less than twenty-five (25) tons per year of actual emissions (after controls) shall be exempt from the requirements specified in 326 IAC 1-7-3(a)." This source has two (2) natural gas-fired boilers that use no. 2 fuel oil as backup only. Thus their actual emissions will be less than 25 tons/year. As a result the source is exempt from 326 IAC 1-7-3(a). No changes have been made to the permit as a result of this comment.

Comment # 3

Section C.13 I need to know what the ERP is and how it would apply. Example, Is this the rule to reduce a given pollutant in times when air quality is poor in a specific area? In addition, how likely would it be to have to reduce the firing rate of the boilers if firing on natural gas. Where can help in writing an ERP be obtained or is it needed for our situation.

Response # 3

Pursuant to 326 IAC 1-5-2, Emergency Reduction Plans are required of, "All persons responsible for the operation of a source that has the potential to emit one hundred (100) tons per year, or more, of any pollutant..." Therefore, an Emergency Reduction Plan is required for this source. IDEM, OAM can be contacted to get help in writing an ERP for this particular source. No changes have been made to the permit as a result of this comment.

Comment # 4

Section D.1.6 As I understand the record keeping requirements, We would need to record the daily fuel usage for the boilers. In addition to this we would have to send in a quarterly report any quarter that we used no. 2 fuel oil and certify that the oil used did not exceed .5% sulfur by weight. Daily stack opacity readings would have to be maintained. I have never seen anything coming out of our boiler stacks. Would we have to have a certified person to read the opacity of the stacks?

Response # 4

A certified person is not required to read the opacity of the stacks. The stacks can be read by a trained employee. A trained employee is an employee who has worked at the plant at least one (1) month and has been trained in the appearance and characteristics of normal visible emissions for that specific process, in this case the opacity of the boiler stacks. No changes have been made to the permit as a result of this comment.

Comment # 5

Annual actual emission statement: Since there is no stack gas monitoring devices on the boilers would we use fuel burned to determine the actual emissions for reporting purposes? Is there a standard form for reporting these to the IDEM?

Response # 5

The amount of fuel burned would be used to determine the actual emissions for reporting purposes. IDEM, OAM should be contacted to determine if there is a standard reporting form. No changes have been made to the permit as a result of this comment.

Appendix A: Emission Calculations

Company Name: Hartford City Paper, L.L.C.
Address City IN Zip: 501 South Spring, Hartford City, IN 47348
CP: 009-7409
Plt ID: 009-00016
Reviewer: Nishat Hydari / EVP

Uncontrolled Potential Emissions (tons/year)			
Emissions Generating Activity			
Pollutant	Natural Gas Combustion (Boiler1 + Boiler 2)	# 2 Fuel Oil Combustion (Boiler 1 + Boiler 2)	TOTAL**
PM	0.94	7.08	7.08
PM10	3.77	0.00	3.77
SO2	0.30	251.45	251.45
NOx	49.58	85.00	85.00
VOC	2.73	0.71	2.73
CO	41.65	17.71	41.65
total HAPs	0.00	0.16	0.16
worst case single HAP	0.00	0.12	0.12
Total emissions based on rated capacity at 8,760 hours/year.			
**Boilers 1 and 2 use nat			
Controlled Potential Emissions (tons/year)			
Emissions Generating Activity			
Pollutant	Natural Gas Combustion (Boiler 1 + Boiler 2)	# 2 Fuel Oil Combustion (Boiler 1 + Boiler 2)	TOTAL**
PM	0.94	2.79	2.79
PM10	3.77	0.00	3.77
SO2	0.30	99.00	99.00
NOx	49.58	33.46	49.58
VOC	2.73	0.28	2.73
CO	41.65	6.97	41.65
total HAPs	0.00	0.16	0.16
worst case single HAP	0.00	0.12	0.12
Total emissions based on rated capacity at 8,760 hours/year, after control.			
**Boilers 1 and 2 use natural gas as the primary fuel and # 2 fuel oil as back up fuel. The total represents the worst c			

Appendix A: Emissions Calculations
Natural Gas Combustion Only
MM BTU/HR <100
Boiler 1 and Boiler 2

Company Name Hartford City Paper, L.L.C.

Address City 1501 South Spring, Hartford City, IN 47348

CP: 009-7409

Plt ID: 009-00016

Reviewer: Nishat Hydari / EVP

Heat Input Capacity
MMBtu/hr

Potential Throughput
MMCF/yr

67.5

591.3

Pollutant

	PM*	PM10*	SO2	NOx	VOC	CO
Emission Factor in lb/MMCF	1.9	7.6	0.6	100.0 **see below	5.5	84.0
Potential Emission in tons/yr	0.56	2.25	0.18	29.57	1.63	24.83

Heat Input Capacity
MMBtu/hr

Potential Throughput
MMCF/yr

45.7

400.3

Pollutant

	PM*	PM10*	SO2	NOx	VOC	CO
Emission Factor in lb/MMCF	1.9	7.6	0.6	100.0 **see below	5.5	84.0
Potential Emission in tons/yr	0.38	1.52	0.12	20.02	1.10	16.81

*PM emission factor is filterable PM only. PM10 emission factor is filterable and condensable PM10 combined.

**Emission Factors for NOx: Uncontrolled = 100, Low NOx Burner = 50, Low NOx Burners/Flue gas recirculation = 32

	PM	PM10	SO2	NOx	VOC	CO
Total Potential Emissions in tons/yr	0.94	3.77	0.30	49.58	2.73	41.65

Methodology

All emission factors are based on normal firing.

MMBtu = 1,000,000 Btu

MMCF = 1,000,000 Cubic Feet of Gas

Potential Throughput (MMCF) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,000 MMBtu

Emission Factors are from AP 42, Chapter 1.4, Tables 1.4-1, 1.4-2, 1.4-3, SCC #1-02-006-02, 1-01-006-02, 1-03-006-02, and 1-03-006-03 (SUPPLEMENT D 3/98)

Emission (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton
emission
factors to

Appendix A: Potential Emissions Calculations**No. 2 Fuel Oil Combustion Only****MM BTU/HR >100****Boiler 1 and Boiler 2****Company Name:** Hartford City Paper, L.L.C.**Address City IN Zip:** 501 South Spring, Hartford City, IN 47348**CP:** 009-7409**Plt ID:** 009-00016**Reviewer:** Nishat Hydari / EVPHeat Input Capacity
MMBtu/hrPotential Throughput
MMCF/yr kgals/year S = Weight % Sulfur

113.2	991.6	7083.1	0.5
-------	-------	--------	-----

Heat Input Capacity includes:

one (1) 67.5 MMBtu/hr boiler and one (1) 45.7 MMBtu/hr boiler, both capable of burning natural gas or No. 2 distillate fuel oil.

	Pollutant				
	PM	SO2	NOx*	VOC	CO
Emission Factor in lb/kgal (No. 2 fuel oil combustion)	2.0	142S	24.00	0.2	5.0
Potential Emissions burning No. 2 fuel oil, tons/yr	7.08	251.45	85.00	0.71	17.71

Heat Input Capacity
MMBtu/hrLimited Throughput
MMCF/yr kgals/year S = Weight % Sulfur

113.2	991.6	2788.68	0.5
-------	-------	---------	-----

Heat Input Capacity includes:

one (1) 67.5 MMBtu/hr boiler and one (1) 45.7 MMBtu/hr boiler, both capable of burning natural gas or No. 2 distillate fuel oil.

	Pollutant				
	PM	SO2	NOx*	VOC	CO
Emission Factor in lb/kgal (No. 2 fuel oil combustion)	2.0	142S	24.00	0.2	5.0

Limited Emissions burning No. 2 fuel oil, tons/yr	2.79	99.00	33.46	0.28	6.97
---	------	-------	-------	------	------

Note:

Limited emissions are based on a No. 2 fuel oil usage limitation of 2,788,680 gallons per year (232,390 gallons per month), and a sulfur content li
Natural gas usage is not limited.

Methodology:

MMBtu = 1,000,000 Btu

MMCF = 1,000,000 Cubic Feet of Gas

Emission Factors for CO from natural gas combustion: Uncontrolled = 35, Low NOx Burner = 61, Flue gas recirculation = 37

Potential Throughput (MMCF) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1 MMCF/1,000 MMBtu

Emission Factors for natural gas combustion are from AP 42, Chapter 1.4, Tables 1.4-1, 1.4-2, 1.4-3, SCC #1-02-006-02

Emissions from natural gas combustion (tons/yr) = Throughput (MMCF/yr) x Emission Factor (lb/MMCF)/2,000 lb/ton

1 gallon of No. 2 Fuel Oil has a heating value of 140,000 Btu

Potential Throughput (kgals/year) = Heat Input Capacity (MMBtu/hr) x 8,760 hrs/yr x 1kgal per 1000 gallon x 1 gal per 0.140 MM Btu

Emission Factors for No. 2 fuel oil combustion are from AP 42, Tables 1.3-2 and 1.3-4 (SCC 1-02-005-01/02/03)

Emissions from No. 2 fuel oil combustion (tons/yr) = Throughput (kgals/ yr) x Emission Factor (lb/kgal)/2,000 lb/ton

Compliance with 326 IAC 7-1.1-2

The following calculations determine the maximum sulfur content of #2 distillate fuel allowed by 326 IAC 7-1-.1-2:

$$\begin{array}{rclcl}
 0.5 \text{ lb/MMBtu} \times & 140,000 & \text{Btu/gal} = & 70 \text{ lb/1000 gal} \\
 70 \text{ lb/1000 gal/} & 142 & \text{lb/1000 gal} = & 0.5 \%
 \end{array}$$

Sulfur content must be less than or equal to 0.5 % to comply with 326 IAC 7-1.1-2.

Facility will comply with 326 IAC 7-1.1-2 by using fuel oil with a limited 0.50% sulfur content.